


Intersection ID: 13227		Main Street: SUNNYSIDE_AV		Cross Street: LAMAR_AV		Location:		SW									
ADA ID: 27103AFD1788		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 17.5									
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance													
 Street 1 Name SUNNYSIDE AV Stop Condition-Street 1 StopSign Street 2 Name N/A Stop Condition-Street 2 N/A				Possible Solutions:		Compliance		Description		Data		Compliance		Description		Data	
				Remove & Replace Entire Ramp. Grind Gutter Lip.		N/A		Ramp Length (in)		35.0		Yes		Grade Break?		Yes	
						Yes		Ramp Width (in)		71.0		No		Grade Break Slope (%)		10.1	
						Yes		Ramp Slope (%)		7.4		Yes		Grade Break XSlope (%)		1.6	
						Yes		Ramp XSlope (%)		1.7							
						N/A		Flare Type LT		N/A		N/A		Flare Type RT		N/A	
						N/A		Flare Slope LT (%)		N/A		N/A		Flare Slope RT (%)		N/A	
						N/A		Flare Traversable LT?		N/A		N/A		Flare Traversable RT?		N/A	
						Yes		Landing Length (in)		72.0		Yes		DWS Provided?		Yes	
						Yes		Landing Width (in)		73.0		Yes		DWS Contrast?		Yes	
		Yes		Landing Slope (%)		1.5		Yes		DWS Length (in)		24.0					
		No		Landing X Slope (%)		2.5		No		DWS Full Width?		No					
		N/A		Landing Curb? (Y/N)		N/A		No		DWS Offset LT (in)		5.0					
		N/A		Shared Landing?		Yes		Yes		DWS Offset RT (in)		10.0					
		Yes		Gutter Ponding?		No		Yes		Gutter Slope (%)		1.4					
		No		Gutter Lip Ht (in)		1.0		Yes		Gutter X Slope (%)		1.9					
		N/A		Painted X Walk1?		No				Road Slope (%)		4.7					
				X Walk 1 Direction		To N				Road X Slope (%)		2.5					
				X Walk 1 Width (in)		N/A				Clear Space?		Yes					
				X Walk 1 Slope (%)		4.7		N/A		Clear Space to XWalk (in)		N/A					
				X Walk 1 X Slope (%)		2.5		Yes		Storm Grate/Utility Hazard?		No					
		N/A		Ramp inside XWalk1?		N/A				Storm Grate/Utility Type							
		Yes		Any Obstructions?		No						N/A					
				Obstruction Type				Yes		Surface Condition? (G/P)		Good					
								N/A		Yes		Curb Slope (%)		5.1			
Total Cost:				\$		1800.00											

