


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 16090	Main Street: SARAH_DR	Cross Street: STEGALL_ST	Location: W
ADA ID: 28EBF6954351	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	

	Possible Solutions:			
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.			
<p>Surveyor Notes:</p> <p>N/A</p>	<p>PROW/ADA:</p> <p>Not Found, R304.5.1, R304.2.2</p>	Compliance	Description	Data
		N/A	Ramp Length (in)	47.0
<p>Street 1 Name</p> <p>SARAH DR</p>	<p>Stop Condition-Street 2</p> <p>None</p>	No	Ramp Width (in)	47.0
		N/A	Flare Type LT	N/A
<p>Street 2 Name</p> <p>STEGALL ST</p>	<p>Stop Condition-Street 1</p> <p>StopSign</p>	N/A	Flare Slope LT (%)	N/A
		N/A	Flare Traversable LT?	N/A
<p>Total Cost:</p> <p>\$ 3200.00</p>		N/A	Landing Length (in)	N/A
		N/A	Landing Width (in)	N/A
		N/A	Landing Slope (%)	N/A
		N/A	Landing X Slope (%)	N/A
		N/A	Landing Curb? (Y/N)	N/A
		N/A	Shared Landing?	N/A
		N/A	Gutter Ponding?	N/A
		N/A	Gutter Lip Ht (in)	N/A
		N/A	Painted X Walk1?	No
			X Walk 1 Direction	To SE
		N/A	X Walk 1 Width (in)	N/A
			X Walk 1 Slope (%)	6.1
			X Walk 1 X Slope (%)	2.0
		N/A	Ramp inside XWalk1?	N/A
			Road Slope (%)	5.1
			Road X Slope (%)	4.7
		N/A	Any Obstructions?	N/A
			Obstruction Type	
		N/A		N/A
		Yes	Surface Condition? (G/P)	Good

