


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: N/A		Main Street: JOHNSTON_RD		Cross Street: N/A		Location:		NW	
ADA ID: 2CA825A3C4C2		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 2.5	
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
<div></div> <div>Possible Solutions:</div> <div>Remove & Replace Entire Ramp.</div> <div>Surveyor Notes:</div> <div>N/A</div> <div>PROW/ADA:</div> <div>R304.2.2-Perp, R304.3.2-Para, R304.5.2, R305.1.4, R305.2</div> <div>Street 1 NameENTRANCE</div> <div>Stop Condition-Street 1StopSign</div> <div>Street 2 NameN/A</div> <div>Stop Condition-Street 2N/A</div> <div>Total Cost:\$1600.00</div>				Compliance	Description	Data	Compliance	Description	Data
				N/A	Ramp Length (in)	96.0	No	Grade Break?	No
				Yes	Ramp Width (in)	58.0	N/A	Grade Break Slope (%)	0.1
				Yes	Ramp Slope (%)	0.9	N/A	Grade Break XSlope (%)	2.1
				Yes	Ramp XSlope (%)	0.9			
				Yes	Flare Type LT	N/A	Yes	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
				Yes	Landing Length (in)	54.0	Yes	DWS Provided?	Yes
				Yes	Landing Width (in)	58.0	Yes	DWS Contrast?	Yes
				No	Landing Slope (%)	3.4	Yes	DWS Length (in)	24.0
				Yes	Landing X Slope (%)	2.0	No	DWS Full Width?	No
				N/A	Landing Curb? (Y/N)	N/A	Yes	DWS Offset LT (in)	37.0
				N/A	Shared Landing?	No	No	DWS Offset RT (in)	4.0
				Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.0
				Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.5
				N/A	Painted X Walk1?	No		Road Slope (%)	0.6
					X Walk 1 Direction	To S		Road X Slope (%)	0.1
					X Walk 1 Width (in)	N/A		Clear Space?	Yes
					X Walk 1 Slope (%)	0.6	N/A	Clear Space to XWalk (in)	N/A
					X Walk 1 X Slope (%)	0.1	Yes	Storm Grate/Utility Hazard?	No
				N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type	
				Yes	Any Obstructions?	No			N/A
					Obstruction Type		Yes	Surface Condition? (G/P)	Good
							N/A	Curb Slope (%)	4.5

Street 1 Name	ENTRANCE
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

