

# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: N/A	Main Street: CRAIGHEAD_RD	Cross Street: N/A	Location: S
ADA ID: 2D8832D87EED	Ramp Type: Combination2Diag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 0	

#### Codes/Mitigation Info/Possible Solution

#### Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.**

Surveyor Notes:

**LT RP < 5%**

PROW/ADA:

**Not Found, R304.2.2, R304.5.3**

Total Cost:

**\$ 3200.00**

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	45.0	N/A	Ramp Length RT (in)	N/A
Yes	Ramp Width LT (in)	63.0	N/A	Ramp Width RT (in)	N/A
Yes	Ramp Slope LT (%)	4.2	N/A	Ramp Slope RT (%)	N/A
No	Ramp XSlope LT (%)	5.7	N/A	Ramp XSlope RT (%)	N/A
N/A	Ramp Length (in)	40.0	No	Ramp Slope (%)	9.0
Yes	Ramp Width (in)	54.0	Yes	Ramp XSlope (%)	1.2
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To E		X Walk 2 Direction	To NW
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	0.7		X Walk 2 Slope (%)	3.7
	X Walk 1 X Slope (%)	2.4		X Walk 2 X Slope (%)	1.3
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	2.1		Clear Space?	N/A
	Road X Slope (%)	1.9	N/A	Clear Space to XWalk (in)	N/A
			N/A	Any Obstruction?	N/A
				Obstruction Type	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
				Storm Grate/Utility Type	N/A
Yes	Surface Condition? (G/P)	Good			
	Curb Slope (%)	7.1			

Street 1 Name: None

Stop Condition-Street 1: CRAIGHEAD RD

Street 2 Name: None

Stop Condition-Street 2: ENTRANCE

