

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 47664	Main Street: ELM_BEND_DR 0			oss Street: WRIGLEY_DR				Location:	NW	
ADA ID: 2DE8375B0F45	Ramp Type: PerpDiag			itial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	8.75	
Codes/Mitigation Info/Possible Solution					Field Measurements/Component Compliance					
VIRICLEY DR C	and the second sec	Possible Solutions:		Comp	mpliance Description		Comp	liance Description	Data	
		Remove & Replace Curb Ramp W	/ith	N/A	Ramp Length (in)	47.0	Yes	Ramp Slope (%)	7.4	
		Two New Directional Ramps or		No	Ramp Width (in)	36.5	Yes	Ramp XSlope (%)	0.5	
		Equivalent.		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
		N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
				N/A	Shared Landing?	N/A				
		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
		R304.5.1		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
				N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	
					X Walk 1 Direction	To S		X Walk 2 Direction	To E	
	The stand of the			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
Street 1 Name	WRIGLEY DR	_			X Walk 1 Slope (%)	0.9		X Walk 2 Slope (%)	2.5	
Stop Condition-Street 2	StopSign				X Walk 1 X Slope (%)	5.1		X Walk 2 X Slope (%)	0.0	
Street 2 Name	ELM BEND DR			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
Stop Condition-Street 1	None				Road Slope (%)	1.6	N/A	Clear Space?	N/A	
					Road X Slope (%)	3.8	N/A	Clear Space to XWalk (in)	N/A	
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
		Total Cost: \$ 32	200.00		Obstruction Type			Storm Grate/Utility Type		
						N/A			N/A	

Yes Surface Condition? (G/P)

Good

