

# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

|                       |                        |                                |                        |
|-----------------------|------------------------|--------------------------------|------------------------|
| Intersection ID: 7380 | Main Street: REAGAN_DR | Cross Street: W_SUGAR_CREEK_RD | Location: NW           |
| ADA ID: 2E034711AC86  | Ramp Type: ParaDiag    | Initial Pass/Fail: Fail        | Overall Compliance: No |
|                       |                        | Severity Score: 12.5           |                        |

#### Codes/Mitigation Info/Possible Solution

#### Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.**

Surveyor Notes:

**LT RP < 5%**

PROW/ADA:

**R304.3.2**

Total Cost:

**\$ 3200.00**

| Compliance | Description          | Data | Compliance | Description                 | Data  |
|------------|----------------------|------|------------|-----------------------------|-------|
| N/A        | Ramp Length LT (in)  | 65.0 | N/A        | Ramp Length RT (in)         | 62.0  |
| Yes        | Ramp Width LT (in)   | 59.5 | Yes        | Ramp Width RT (in)          | 59.5  |
| Yes        | Ramp Slope LT (%)    | 3.4  | No         | Ramp Slope RT (%)           | 8.4   |
| Yes        | Ramp XSlope LT (%)   | 1.6  | Yes        | Ramp XSlope RT (%)          | 0.2   |
| N/A        | Landing Length (in)  | N/A  | N/A        | DWS Provided?               | N/A   |
| N/A        | Landing Width (in)   | N/A  | N/A        | DWS Contrast?               | N/A   |
| N/A        | Landing Slope (%)    | N/A  | N/A        | DWS Length (in)             | N/A   |
| N/A        | Landing X Slope (%)  | N/A  | N/A        | DWS Full Width?             | N/A   |
| N/A        | Landing Curb? (Y/N)  | N/A  | N/A        | DWS Offset (in)             | N/A   |
| N/A        | Shared Landing?      | N/A  |            |                             |       |
| N/A        | Gutter Ponding?      | N/A  | N/A        | Gutter Slope (%)            | N/A   |
| N/A        | Gutter Lip Ht (in)   | N/A  | N/A        | Gutter X Slope (%)          | N/A   |
| N/A        | Painted X Walk1?     | Yes  | N/A        | Painted X Walk2?            | Yes   |
|            | X Walk 1 Direction   | To S |            | X Walk 2 Direction          | To E  |
| N/A        | X Walk 1 Width (in)  | 99.5 | N/A        | X Walk 2 Width (in)         | 414.0 |
|            | X Walk 1 Slope (%)   | 0.5  |            | X Walk 2 Slope (%)          | 1.7   |
|            | X Walk 1 X Slope (%) | 2.7  |            | X Walk 2 X Slope (%)        | 0.3   |
| N/A        | Ramp inside XWalk1?  | Yes  | N/A        | Ramp inside XWalk2?         | Yes   |
|            | Road Slope (%)       | 1.5  | N/A        | Clear Space?                | N/A   |
|            | Road X Slope (%)     | 1.4  | N/A        | Clear Space to XWalk (in)   | N/A   |
| N/A        | Any Obstructions?    | N/A  | N/A        | Storm Grate/Utility Hazard? | N/A   |
|            | Obstruction Type     |      |            | Storm Grate/Utility Type    |       |
|            |                      | N/A  |            |                             | N/A   |
|            |                      |      | Yes        | Surface Condition? (G/P)    | Good  |
|            |                      |      | N/A        | Curb Slope (%)              | 14.8  |

Street 1 Name **REAGAN DR**  
 Stop Condition-Street 1 **Signal**  
 Street 2 Name **W SUGAR CREEK RD**  
 Stop Condition-Street 2 **Signal**

