

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Yes

Surface Condition? (G/P)

Good

Intersection ID: 2812	Main Street: ROCK_STREAM_DR			Cross Street: TESH_CT				Location:	SW
ADA ID: 2EC89B89473B	Ramp Type: Perp			Initial Pass/Fail: Fail Overall Compliance:			nce: N	o Severity Score:	37.5
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
18 B	Po	Possible Solutions:		Compliance Description			Data Compliance Description		
	F	Remove & Replace Entire R	amp.	N/A	Ramp Length (in)	95.0	No	Ramp Slope (%)	9.8
		·	•	Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	8.3
Salara Maria				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
	-			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
TESTIGI C	20 23			N/A	Flare Traversable L	T? N/A	N/A	Flare Traversable RT?	N/A
	1			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
	Su	urveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
	CA LA			N/A	Landing X Slope (%) N/A	N/A	DWS Full Width?	N/A
	A			N/A	Landing Curb? (Y/N	I) N/A	N/A	DWS Offset (in)	N/A
	and the second second			N/A	Shared Landing?	N/A			
	PR	ROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
and a start of the start of the		Not Found, R304.2.2, R304.5	.3	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
		,,		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	1 Second				X Walk 1 Direction	To N		X Walk 2 Direction	N/A
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name T	TESH CT				X Walk 1 Slope (%)	2.4		X Walk 2 Slope (%)	N/A
Stop Condition-Street 2 S	StopSign				X Walk 1 X Slope (%	%) 4.0		X Walk 2 X Slope (%)	N/A
Street 2 Name	N/A			N/A	Ramp inside XWalk	1? N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	N/A				Road Slope (%)	4.0	N/A	Clear Space?	N/A
					Road X Slope (%)	2.4	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Tot	stal Cost: \$	1850.0	00	Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A