


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 2853		Main Street: CARDINAL_POINT_RD		Cross Street: BENFIELD_RD		Location:		SE					
ADA ID: 30A3B21C4FBC		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 5					
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance									
 Street 1 NameCARDINAL POINT DR Stop Condition-Street 1StopSign Street 2 NameN/A Stop Condition-Street 2N/A				Possible Solutions:		Compliance		Description		Data			
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		64.0		No	
						Yes		Ramp Width (in)		68.0		N/A	
						Yes		Ramp Slope (%)		6.0		N/A	
						Yes		Ramp XSlope (%)		1.5			
						Yes		Flare Type LT		N/A		No	
						N/A		Flare Slope LT (%)		N/A		N/A	
						N/A		Flare Traversable LT?		No		N/A	
						Yes		Landing Length (in)		81.0		Yes	
						Yes		Landing Width (in)		71.5		Yes	
		Yes		Landing Slope (%)		0.5		Yes					
		Yes		Landing X Slope (%)		0.6		Yes					
		N/A		Landing Curb? (Y/N)		N/A		Yes					
		N/A		Shared Landing?		Yes		Yes					
		Yes		Gutter Ponding?		No		Yes					
		Yes		Gutter Lip Ht (in)		0.0		Yes					
		N/A		Painted X Walk1?		Yes							
				X Walk 1 Direction		To N							
				X Walk 1 Width (in)		103.0							
				X Walk 1 Slope (%)		0.8		N/A					
				X Walk 1 X Slope (%)		1.9		Yes					
		Yes		Ramp inside XWalk1?		Yes							
		Yes		Any Obstructions?		No							
				Obstruction Type				Yes					
						N/A		No					
								Yes					
								No					

