


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 46820	Main Street: NORWAY_SPRUCE_CT	Cross Street: AZALEA_HILLS_DR	Location: S
ADA ID: 32974FA4181F	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 33.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	49.0
			No	Ramp Width (in)	43.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
Surveyor Notes: N/A PROW/ADA: R304.5.1, R304.2.2			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To NE
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	2.4
				X Walk 1 X Slope (%)	1.2
			N/A	Ramp inside XWalk1?	N/A
				Road Slope (%)	N/A
				Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
Total Cost:		\$ 1850.00			
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

