


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 50543	Main Street: ALCEA_ST	Cross Street: DANIEL_DWAYNE_DR	Location: W
ADA ID: 32A129EA436A	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 15.25	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Remove & Replace Gutter.		N/A	Ramp Length (in)	47.0	Yes	Ramp Slope (%)	7.8
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	3.0
			N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	1.2	Yes	Flare Slope RT (%)	6.1
			N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
			Yes	Landing Length (in)	48.0	Yes	DWS Provided?	Yes
			Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes
			Yes	Landing Slope (%)	0.5	Yes	DWS Length (in)	25.0
			No	Landing X Slope (%)	4.2	No	DWS Full Width?	No
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	6.0
PROW/ADA:		Not Found, R304.5.3, R305.1.4, R305.2, R302.7.2, R304.5.4		N/A	Shared Landing?	No		
			Yes	Gutter Ponding?	No	No	Gutter Slope (%)	13.1
			No	Gutter Lip Ht (in)	0.5	No	Gutter X Slope (%)	3.5
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
				X Walk 1 Direction	To S		X Walk 2 Direction	To N
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	4.9		X Walk 2 Slope (%)	2.5
				X Walk 1 X Slope (%)	0.2		X Walk 2 X Slope (%)	5.7
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	4.5	N/A	Clear Space?	Yes
				Road X Slope (%)	3.8	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
				Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good

Street 1 Name	ALCEA ST
Stop Condition-Street 2	StopSign
Street 2 Name	DANIEL DWAYNE DR
Stop Condition-Street 1	None

Total Cost: \$ 3950.00

