

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 25768	Main Street: JOHNSTON_RD	Cross Street: PINEVILLE-MATTHEWS_RD	Location: SW
ADA ID: 330393A261E7	Ramp Type: ParaDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

R304.3.2, R304.5.3

Street 1 Name	JOHNSTON RD
Stop Condition-Street 1	Signal
Street 2 Name	PINEVILLE-MATTHEWS RD
Stop Condition-Street 2	Signal

Total Cost: \$ 3200.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	55.0	N/A	Ramp Length RT (in)	66.0
Yes	Ramp Width LT (in)	60.0	Yes	Ramp Width RT (in)	60.0
No	Ramp Slope LT (%)	8.4	Yes	Ramp Slope RT (%)	5.9
Yes	Ramp XSlope LT (%)	0.4	No	Ramp XSlope RT (%)	2.1
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To E		X Walk 2 Direction	To N
N/A	X Walk 1 Width (in)	96.0	N/A	X Walk 2 Width (in)	119.0
	X Walk 1 Slope (%)	0.1		X Walk 2 Slope (%)	1.5
	X Walk 1 X Slope (%)	1.8		X Walk 2 X Slope (%)	0.9
N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	Yes
	Road Slope (%)	1.6	N/A	Clear Space?	N/A
	Road X Slope (%)	1.0	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	7.3

