


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 53281	Main Street: BENFIELD_RD	Cross Street: CRAVEN_THOMAS_RD	Location:	N
ADA ID: 33554F79D606	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 8.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	89.5
			No	Ramp Width (in)	47.5
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.5.1</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Slope (%)	N/A
			N/A	Gutter X Slope (%)	N/A
<p>Total Cost:</p> <p>\$ 1850.00</p>			N/A	Painted X Walk1?	N/A
			N/A	Painted X Walk2?	N/A
			N/A	X Walk 1 Direction	To W
			N/A	X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	104.5
			N/A	X Walk 2 Width (in)	N/A
			N/A	X Walk 1 Slope (%)	0.7
			N/A	X Walk 2 Slope (%)	N/A
			N/A	X Walk 1 X Slope (%)	1.5
			N/A	X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	Yes
			N/A	Ramp inside XWalk2?	N/A
			N/A	Clear Space?	N/A
			N/A	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Storm Grate/Utility Type	N/A
			N/A	Surface Condition? (G/P)	Good
			N/A		
			N/A		
			N/A		

