


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10016180	Main Street: OAKLAWN_AV	Cross Street: MCCALL_ST	Location: NW
ADA ID: 337C2ACB330F	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 8.75	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		Yes	Ramp Length (in)	6.9
			No	Ramp Width (in)	0.8
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>Not Found, R304.5.1</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			No	Painted X Walk1?	No
				X Walk 1 Direction	To S
			N/A	X Walk 1 Width (in)	N/A
			0.7	X Walk 1 Slope (%)	0.3
			0.8	X Walk 1 X Slope (%)	1.9
			N/A	Ramp inside XWalk1?	N/A
			0.0	Road Slope (%)	N/A
			1.6	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
			N/A	Obstruction Type	N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
			N/A		N/A
Total Cost:			\$	3200.00	

Street 1 Name **OAKLAWN AV**

Stop Condition-Street 2 **None**

Street 2 Name **MCCALL ST**

Stop Condition-Street 1 **StopSign**

