


## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Intersection ID: 14852 Main Street: HARRISBURG RD **Cross Street: SHACKLEFORD TR** Location: SW ADA ID: 358004A28F5A Ramp Type: PerpDiag Initial Pass/Fail: Fail **Overall Compliance: No Severity Score:** 12.5

**Codes/Mitigation Info/Possible Solution** 

## Field Measurements/Component Compliance



Street 1 Name Stop Condition-Street 2 Street 2 Name Stop Condition-Street 1

HARRISBURG RD StopSign SHACKLEFORD TR StopSign

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

N/A

PROW/ADA:

Not Found, R304.2.2


Total Cost:

Compliance Description Date		Data	Compliance Description		Data
N/A	Ramp Length (in)	47.0	No	Ramp Slope (%)	10.8
Yes	Ramp Width (in)	96.0	Yes	Ramp XSlope (%)	0.6
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To SE		X Walk 2 Direction	To NE
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	1.3		X Walk 2 Slope (%)	0.4
	X Walk 1 X Slope (%)	0.7		X Walk 2 X Slope (%)	0.5
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	0.4	N/A	Clear Space?	N/A
	Road X Slope (%)	0.5	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A

Yes

Surface Condition? (G/P)

Good







3200.00