


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 11263	Main Street: W_TRADE_ST	Cross Street: S_SYCAMORE_ST	Location: SW
ADA ID: 364F7DB4557D	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
			Severity Score: 40.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
 Street 1 Name S SYCAMORE ST Stop Condition-Street 2 StopSign Street 2 Name W TRADE ST Stop Condition-Street 1 None	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Remove & Replace Gutter.		N/A	Ramp Length (in)	88.0	Yes	Ramp Slope (%)	5.5
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	2.4
			N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	6.4	Yes	Flare Slope RT (%)	8.5
			N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
			No	Landing Length (in)	N/A	No	DWS Provided?	No
			No	Landing Width (in)	N/A	N/A	DWS Contrast?	No
			No	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			No	Landing X Slope (%)	N/A	N/A	DWS Full Width?	No
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	No	N/A	DWS Offset (in)	N/A
PROW/ADA:		Not Found, R304.5.3, R304.2.1, R304.2.2-Perp, R304.3.2-Para, R305, R302.7, R302.7.2, R304.5.4	N/A	Shared Landing?	No			
Total Cost:		\$ 3950.00	No	Gutter Ponding?	Yes	No	Gutter Slope (%)	6.6
			No	Gutter Lip Ht (in)	1.5	Yes	Gutter X Slope (%)	0.1
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
				X Walk 1 Direction	To E		X Walk 2 Direction	To N
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	7.5		X Walk 2 Slope (%)	9.2
				X Walk 1 X Slope (%)	2.7		X Walk 2 X Slope (%)	1.5
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	0.3	N/A	Clear Space?	Yes
				Road X Slope (%)	7.0	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
				Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good

