

Intersection ID: 28694	Main Street: SWEARNGAN_RD	Cross Street: HUDSON_GRAHAM_LN	Location:	S
ADA ID: 3781BBCCD26C	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 47.5

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



### Possible Solutions:

### Remove & Replace Entire Ramp.

Surveyor Notes:

**N/A**

PROW/ADA:

**Not Found, R304.5.1, R304.2.2**

Possible Solutions:			Compliance	Description	Data	Compliance	Description	Data
<b>Remove &amp; Replace Entire Ramp.</b>			N/A	Ramp Length (in)	96.5	No	Ramp Slope (%)	9.6
			No	Ramp Width (in)	27.5	Yes	Ramp XSlope (%)	2.0
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
Surveyor Notes:			N/A	Shared Landing?	N/A			
PROW/ADA:			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
<b>Not Found, R304.5.1, R304.2.2</b>			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To NE		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	0.9		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	2.1		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	N/A	N/A	Clear Space?	N/A
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
Total Cost:	\$	1850.00		Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good

Total Cost: \$ 1850.00

Street 1 Name	HUDSON GRAHAM LN
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

