

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 10033483 Main Street: OLD_PINEVILLE_RD Cross Street: N/A Location: NE Ramp Type: Directional1 **Overall Compliance: No** ADA ID: 37CA975263CF Initial Pass/Fail: Fail **Severity Score:** 1.25

Codes/Mitigation Info/Possible Solution



Street 1 Name **ENTRANCE** Stop Condition-Street 1 StopSign Street 2 Name N/A Stop Condition-Street 2 N/A

Possible Solutions:						
Remove & Replace Entire Ramp.						
•						
Surveyor Notes:						
N/A						
PROW/ADA:						
R304.5.3						

Total Cost:	\$ 1600.00

Field Measurements/Component Compliance							
Comp	liance Description	Data	Comp	liance Description	Data		
N/A	Ramp Length (in)	99.0	N/A	Grade Break?	N/A		
Yes	Ramp Width (in)	67.5	N/A	Grade Break Slope (%)	0.0		
Yes	Ramp Slope (%)	6.0	N/A	Grade Break XSlope (%)	0.0		
No	Ramp XSlope (%)	3.0					
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A		
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	0.0		
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A		
N/A	Landing Length (in)	0.0	N/A	DWS Provided?	N/A		
N/A	Landing Width (in)	0.0	N/A	DWS Contrast?	N/A		
N/A	Landing Slope (%)	0.0	N/A	DWS Length (in)	N/A		
N/A	Landing X Slope (%)	0.0	N/A	DWS Full Width?	N/A		
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset LT (in)	N/A		
N/A	Shared Landing?	N/A	N/A	DWS Offset RT (in)	N/A		
N/A	Gutter Ponding?	0.0	N/A	Gutter Slope (%)	N/A		
N/A	Gutter Lip Ht (in)	0.0	N/A	Gutter X Slope (%)	N/A		
N/A	Painted X Walk1?	Yes		Road Slope (%)	7.2		
	X Walk 1 Direction	To W		Road X Slope (%)	2.5		
	X Walk 1 Width (in)	88.0		Clear Space?	N/A		
	X Walk 1 Slope (%)	7.2	N/A	Clear Space to XWalk (in)	N/A		
	X Walk 1 X Slope (%)	2.5	N/A	Storm Grate/Utility Hazard?	N/A		
N/A	Ramp inside XWalk1?	Yes		Storm Grate/Utility Type			
N/A	Any Obstructions?	N/A			N/A		
	Obstruction Type		Yes	Surface Condition? (G/P)	Good		
		N/A	N/A	Curb Slope (%)	11.0		





