


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: N/A	Main Street: E_4TH_ST	Cross Street: N/A	Location: SW
ADA ID: 3A1C784B3C97	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		<b>Compliance</b>			<b>Description</b>			<b>Data</b>	
	<b>Remove &amp; Replace Entire Ramp.</b>		<b>N/A</b>	Ramp Length (in)	<b>73.5</b>	<b>No</b>	Ramp Slope (%)	<b>10.1</b>		
			<b>Yes</b>	Ramp Width (in)	<b>72.0</b>	<b>Yes</b>	Ramp XSlope (%)	<b>1.7</b>		
			<b>N/A</b>	Flare Type LT	<b>N/A</b>	<b>N/A</b>	Flare Type RT	<b>N/A</b>		
			<b>N/A</b>	Flare Slope LT (%)	<b>N/A</b>	<b>N/A</b>	Flare Slope RT (%)	<b>N/A</b>		
			<b>N/A</b>	Flare Traversable LT?	<b>No</b>	<b>N/A</b>	Flare Traversable RT?	<b>No</b>		
			<b>N/A</b>	Landing Length (in)	<b>N/A</b>	<b>N/A</b>	DWS Provided?	<b>N/A</b>		
			<b>N/A</b>	Landing Width (in)	<b>N/A</b>	<b>N/A</b>	DWS Contrast?	<b>N/A</b>		
			<b>N/A</b>	Landing Slope (%)	<b>N/A</b>	<b>N/A</b>	DWS Length (in)	<b>N/A</b>		
			<b>N/A</b>	Landing X Slope (%)	<b>N/A</b>	<b>N/A</b>	DWS Full Width?	<b>N/A</b>		
Surveyor Notes:		<b>N/A</b>			<b>N/A</b>	DWS Offset (in)	<b>N/A</b>	<b>N/A</b>		
PROW/ADA:		<b>R304.2.2</b>			<b>N/A</b>	Shared Landing?	<b>N/A</b>			
					<b>N/A</b>	Gutter Ponding?	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
					<b>N/A</b>	Gutter Lip Ht (in)	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
					<b>N/A</b>	Painted X Walk1?	<b>No</b>	<b>N/A</b>	<b>N/A</b>	
						X Walk 1 Direction	<b>To NW</b>		<b>N/A</b>	
					<b>N/A</b>	X Walk 1 Width (in)	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
						X Walk 1 Slope (%)	<b>2.2</b>		<b>N/A</b>	
						X Walk 1 X Slope (%)	<b>0.2</b>		<b>N/A</b>	
					<b>N/A</b>	Ramp inside XWalk1?	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
						Road Slope (%)	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
						Road X Slope (%)	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
					<b>N/A</b>	Any Obstructions?	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	
						Obstruction Type				
							<b>N/A</b>		<b>N/A</b>	
							<b>Yes</b>	Surface Condition? (G/P)	<b>Good</b>	
Street 1 Name		<b>ENTRANCE</b>								
Stop Condition-Street 2		<b>None</b>								
Street 2 Name		<b>N/A</b>								
Stop Condition-Street 1		<b>N/A</b>								
Total Cost:		\$ 1850.00								

