

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

59.5

72.0

13.5

2.6

3.8

5.5


N/A

Good 12.2

Intersection ID: 50203 Main Street: WEDDINGTON_RD Cross Street: COLTSVIEW_LN Location: NW
ADA ID: 3B4349631F69 Ramp Type: Combination1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 37.5

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
StopSign
Stop Condition-Street 1
COTSVIEW LN
Street 2 Name
N/A
Stop Condition-Street 2
N/A

Possible Solutions:

Remove & Replace Entire Ramp.


Surveyor Notes:

RP & LT RP < 5%

PROW/ADA:

Not Found, R304.5.3, R304.3.2

Total Cost: \$



6.0

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Yes

X Walk 2 X Slope (%)

Ramp inside XWalk2?

Clear Space to XWalk (in)

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)

Clear Space?

Any Obstruction?

Obstruction Type

Curb Slope (%)







N/A

1800.00

X Walk 1 X Slope (%)

Ramp inside XWalk1?

Road Slope (%)