


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 25907	Main Street: CHALLIS_HILL_LN	Cross Street: OLD_WELL_HOUSE_RD	Location: E
ADA ID: 3B452AD1B441	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance						
 <p>Street 1 Name CHALLUS HILL LN</p> <p>Stop Condition-Street 2 StopSign</p> <p>Street 2 Name OLD WELL HOUSE RD</p> <p>Stop Condition-Street 1 None</p>	Possible Solutions:							
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.							
	Surveyor Notes:							
	N/A							
	PROW/ADA:							
	R304.2.2, R304.5.3							

