

Access Compliance Report


Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10025871	Main Street: ELEVATION_POINT_DR	Cross Street: N/A	Location:	N
ADA ID: 3C087194755A	Ramp Type: Combination1	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score: 0.25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Entire Ramp.
Remove & Replace Gutter.**

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.3

Total Cost:

\$ 2550.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	68.0	N/A	Ramp Length RT (in)	62.0
Yes	Ramp Width LT (in)	93.0	Yes	Ramp Width RT (in)	94.0
Yes	Ramp Slope LT (%)	5.2	Yes	Ramp Slope RT (%)	8.3
No	Ramp XSlope LT (%)	2.1	No	Ramp XSlope RT (%)	3.4
N/A	Ramp Length (in)	38.0	Yes	Ramp Slope (%)	5.0
Yes	Ramp Width (in)	57.0	No	Ramp XSlope (%)	2.1
Yes	Flare Type LCurbed_NoWalkSurface		Yes	Flare Type RCurbed_NoWalkSurface	
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
Yes	Landing Length (in)	101.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	70.5	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	0.9	Yes	DWS Length (in)	24.0
No	Landing X Slope (%)	2.9	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	Yes	Yes	DWS Offset (in)	0.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.7
Yes	Gutter Lip Ht (in)	0.0	No	Gutter X Slope (%)	2.7
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To S		X Walk 2 Direction	N/A
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	1.9		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	1.1		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A		Clear Space?	Yes
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstruction?	No
				Obstruction Type	N/A
			Yes	Storm Grate/Utility Hazard?	No
				Storm Grate/Utility Type	N/A
			Yes	Surface Condition? (G/P)	Good
				Curb Slope (%)	6.9

Street 1 Name	None
Stop Condition-Street 1	ELEVATION POINT DR
Street 2 Name	N/A
Stop Condition-Street 2	N/A

