

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Main Street: ERIE ST Intersection ID: 8500 **Cross Street: LASALLE ST** Location: SE

Initial Pass/Fail: Fail **Overall Compliance: No ADA ID: 3D7FFF66AFED** Ramp Type: PerpDiag Severity Score: 33.75

Codes/Mitigation Info/Possible Solution

None

ERIE ST

Field Measurements/Component Compliance



LASALLE ST Street 1 Name Stop Condition-Street 2 Street 2 Name Stop Condition-Street 1 StopSign Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Possible Solutions:

				N/A
				N/A
				N/A
Surveyor Notes:				N/A
N/A				N/A
				N/A
				N/A
				N/A
PROW/ADA:				N/A
Not Found,	R304.5.1, R304.5	5.3		N/A
				N/A
Total Cost:	\$		3200.00	









