cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



· · · · · · · · · · · · · · · · · · ·								
Intersection ID: 10039876 Main S	ection ID: 10039876 Main Street: TOWNSHIP_RD		Cross Street: N/A				SW	
ADA ID: 3F4602EE176E Ramp	2EE176E Ramp Type: PerpDiag		Initial Pass/Fail: Fail Overall Compliance: No			o Severity Score:	12.5	
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:	Com	Compliance Description		Data Compliance Description		Data	
	Remove & Replace Curb Ramp W	ith N/A	Ramp Length (in)	41.0	Yes	Ramp Slope (%)	6.0	
	Two New Directional Ramps or	Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	5.8	
	Equivalent.	N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
		N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
	2	N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
		N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
	Surveyor Notes:	N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
	N/A	N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
		N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
No the second se		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
		N/A	Shared Landing?	N/A				
	PROW/ADA:	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
	R304.5.3	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	
			X Walk 1 Direction	To NE		X Walk 2 Direction	To NW	
		N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
Street 1 Name TOWNSHIP RI)		X Walk 1 Slope (%)	4.1		X Walk 2 Slope (%)	1.9	
Stop Condition-Street 2 Non	9		X Walk 1 X Slope (%)	0.5		X Walk 2 X Slope (%)	2.4	
Street 2 Name ENTRANCI	E	N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
Stop Condition-Street 1 StopSig	1		Road Slope (%)	2.3	N/A	Clear Space?	N/A	
			Road X Slope (%)	1.7	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Total Cost: \$ 32	00.00	Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	

Yes Surface Condition? (G/P)

Good

