

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 45756 Main Street: CHRISTENBURY_RD Cross Street: GRANDEUR_RD Location: NW

ADA ID: 3F4AC1FFA312 Ramp Type: PerpDiag Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 33.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
Stop Condition-Street 2
Street 2 Name
Stop Condition-Street 1

CHRISTENBURY RD None GRANDEUR RD StopSign Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.1, R304.2.2

Total Cost: \$ 3200.00

9	Compliance	iance Description		Compliance Description		Description	Data
N	N/A Ram	np Length (in)	47.0	No	Ramp	Slope (%)	18.8
N	No Ram	np Width (in)	41.0	Yes	Ramp	XSlope (%)	1.4
N	\/A Flar	e Type LT	N/A	N/A	Flare	Type RT	N/A
N	N/A Flar	e Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	N/A
N	N/A Flar	e Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A
N	N/A Land	ding Length (in)	N/A	N/A	DWS	Provided?	N/A
N	N/A Land	ding Width (in)	N/A	N/A	DWS	Contrast?	N/A
N	N/A Land	ding Slope (%)	N/A	N/A	DWS	Length (in)	N/A
N	N/A Land	ding X Slope (%)	N/A	N/A	DWS	Full Width?	N/A
N	N/A Land	ding Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A
N	N/A Sha	red Landing?	N/A				
N	N/A Gutt	ter Ponding?	N/A	N/A	Gutte	r Slope (%)	N/A
N	I/A Gutt	er Lip Ht (in)	N/A	N/A	Gutte	r X Slope (%)	N/A
N	N/A Pain	ited X Walk1?	No	N/A	Painte	ed X Walk2?	No
	ΧW	alk 1 Direction	To S		X Wa	lk 2 Direction	To E
N	N/A XW	alk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A
	ΧW	alk 1 Slope (%)	2.4		X Wa	lk 2 Slope (%)	2.0
	ΧW	alk 1 X Slope (%)	1.0		X Wa	lk 2 X Slope (%)	6.2
N	N/A Ram	np inside XWalk1?	N/A	N/A	Ramp	inside XWalk2?	N/A
	Roa	d Slope (%)	2.8	N/A	Clear	Space?	N/A
	Roa	d X Slope (%)	3.3	N/A	Clear	Space to XWalk (in)	N/A
N	N/A Any	Obstructions?	N/A	N/A	Storm	Grate/Utility Hazard?	N/A
	Obs	truction Type			Storm	Grate/Utility Type	
			N/A				N/A
				Yes	Surfa	ce Condition? (G/P)	Good





