


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 7436	Main Street: N_HOSKINS_RD	Cross Street: CARRIER_DR	Location: SE
ADA ID: 3FFD9854825B	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 25	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance									
	Possible Solutions:		Compliance			Description			Data			
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)		59.5		No	Ramp Slope (%)		12.1	
			Yes	Ramp Width (in)		48.0		Yes	Ramp XSlope (%)		1.0	
			N/A	Flare Type LT		N/A		N/A	Flare Type RT		N/A	
			N/A	Flare Slope LT (%)		N/A		N/A	Flare Slope RT (%)		N/A	
			N/A	Flare Traversable LT?		N/A		N/A	Flare Traversable RT?		N/A	
			N/A	Landing Length (in)		N/A		N/A	DWS Provided?		N/A	
			N/A	Landing Width (in)		N/A		N/A	DWS Contrast?		N/A	
			N/A	Landing Slope (%)		N/A		N/A	DWS Length (in)		N/A	
			N/A	Landing X Slope (%)		N/A		N/A	DWS Full Width?		N/A	
Surveyor Notes:					N/A							
PROW/ADA:					Not Found, R304.2.2							
Street 1 Name					N HOSKINS RD							
Stop Condition-Street 2					None							
Street 2 Name					N/A							
Stop Condition-Street 1					N/A							
Total Cost:					\$ 1850.00							
							</					

