

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 2983 Main Street: YELLOW_ROSE_LN Cross Street: BROWNE_RD Location: SE

ADA ID: 40942C3191B9 Ramp Type: Perp Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name BROWNE RD
Stop Condition-Street 2 None
Street 2 Name N/A
Stop Condition-Street 1 N/A

Possible Solutions:

Remove & Replace Entire Ramp.

N

N

Surveyor Notes:

N/A

N

PROW/ADA:

R304.2.2

Total Cost: \$ 1850.00

Compliance Description <u>Data</u> Compliance Description Data No Ramp Slope (%) N/A Ramp Length (in) 63.0 12.5 Yes Ramp XSlope (%) Yes Ramp Width (in) 48.0 1.8 N/A N/A Flare Type LT N/A Flare Type RT N/A N/A N/A N/A Flare Slope RT (%) N/A Flare Slope LT (%) N/A Flare Traversable LT? N/A N/A Flare Traversable RT? N/A N/A N/A N/A **DWS Provided?** N/A Landing Length (in) N/A Landing Width (in) N/A N/A **DWS Contrast?** N/A N/A N/A N/A Landing Slope (%) DWS Length (in) N/A N/A Landing X Slope (%) N/A N/A DWS Full Width? N/A N/A Landing Curb? (Y/N) N/A N/A DWS Offset (in) N/A N/A N/A Shared Landing? N/A **Gutter Ponding?** N/A N/A Gutter Slope (%) N/A N/A Gutter Lip Ht (in) N/A N/A Gutter X Slope (%) N/A N/A Painted X Walk1? Yes N/A Painted X Walk2? N/A X Walk 1 Direction To W X Walk 2 Direction N/A N/A 108.0 N/A X Walk 1 Width (in) X Walk 2 Width (in) N/A X Walk 1 Slope (%) 2.4 X Walk 2 Slope (%) N/A X Walk 1 X Slope (%) 0.1 X Walk 2 X Slope (%) N/A N/A N/A Ramp inside XWalk2? Ramp inside XWalk1? Yes N/A Road Slope (%) N/A N/A Clear Space? N/A N/A Road X Slope (%) N/A Clear Space to XWalk (in) N/A N/A N/A Any Obstructions? N/A Storm Grate/Utility Hazard? N/A **Obstruction Type** Storm Grate/Utility Type N/A N/A Yes Surface Condition? (G/P) Good





