

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Data

48.0

60.0

10.9

1.8

7.9

5.8

N/A

Intersection ID: 6829 Main Street: PRINCESS ST Cross Street: W SUGAR CREEK RD Location: SW ADA ID: 413F4D17C034 Ramp Type: Combination1 Initial Pass/Fail: Fail **Overall Compliance: No** Severity Score: 33.75

1800.00

**Codes/Mitigation Info/Possible Solution** 

## Field Measurements/Component Compliance

N/A

Yes

No

Yes

Yes

No

N/A

Compliance Description

Ramp Length RT (in)

Ramp Width RT (in)

Ramp Slope RT (%)

Ramp XSlope RT (%)

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

**DWS Contrast?** 

DWS Length (in)

DWS Full Width?

DWS Offset (in)

Gutter Slope (%)

Gutter X Slope (%)

Painted X Walk2?

X Walk 2 Direction

X Walk 2 Width (in)

X Walk 2 Slope (%)

X Walk 2 X Slope (%)

Ramp inside XWalk2?

Clear Space?

Flare Traversable RT?

Data

48.0

58.0

1.6

2.0

24.0

45.5

N/A

No

To N

N/A

2.2

3.0

N/A

N/A

Ramp Length LT (in)

Ramp Width LT (in)

Ramp Slope LT (%)

Ramp Length (in)

Ramp Width (in)

Flare Slope LT (%)

Landing Length (in)

Landing Width (in)

Landing Slope (%)

Landing X Slope (%)

Landing Curb? (Y/N)

Shared Landing?

Gutter Ponding?

Gutter Lip Ht (in)

Flare Traversable LT?

Flare Type LT

Ramp XSlope LT (%)



StopSign Street 1 Name Stop Condition-Street 1 PRINCESS ST N/A Street 2 Name Stop Condition-Street 2 N/A

Compliance Description Possible Solutions: N/A Remove & Replace Entire Ramp. Yes Yes Yes N/A No Surveyor Notes: N/A **GTR GAP 2.0, LT RP < 5%** N/A N/A N/A N/A PROW/ADA N/A Not Found, R304.5.1, R304.5.3, N/A R304.3.2 N/A N/A N/A N/A



Road X Slope (%) N/A N/A Clear Space to XWalk (in) N/A N/A Any Obstruction? N/A **Obstruction Type** N/A N/A Storm Grate/Utility Hazard? N/A Storm Grate/Utility Type N/A Yes Surface Condition? (G/P) Good 27.7 Curb Slope (%)





Total Cost: