


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 2937	Main Street: RIDGE_RD	Cross Street: STREET_AV	Location:	N
ADA ID: 41613975F14A	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score: 0

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		Compliance			Description			Data	
	Remove & Replace Landing.		N/A	Ramp Length (in)	47.0	Yes	Ramp Slope (%)	6.5		
			Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	1.6		
			N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A		
			N/A	Flare Slope LT (%)	10.0	Yes	Flare Slope RT (%)	7.1		
			N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes		
			Yes	Landing Length (in)	60.0	Yes	DWS Provided?	Yes		
			Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes		
			Yes	Landing Slope (%)	1.4	Yes	DWS Length (in)	24.5		
			No	Landing X Slope (%)	2.3	Yes	DWS Full Width?	Yes		
Surveyor Notes: N/A PROW/ADA: R304.5.3				N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	1.0	
				N/A	Shared Landing?	No				
				Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	4.3	
				Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.3	
				N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A	
					X Walk 1 Direction	To SW		X Walk 2 Direction	N/A	
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
					X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	N/A	
					X Walk 1 X Slope (%)	0.9		X Walk 2 X Slope (%)	N/A	
				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
				Road Slope (%)	N/A	N/A	Clear Space?	Yes		
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A		
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No		
				Obstruction Type			Storm Grate/Utility Type			
						N/A		N/A		
						Yes	Surface Condition? (G/P)	Good		

Street 1 Name	RIDGE RD
Stop Condition-Street 2	None
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Total Cost:	\$	500.00
-------------	----	--------

