


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 42737	Main Street: CALDWELL_FOREST_DR	Cross Street: CARLEEN_WAY_DR	Location:	N
ADA ID: 449CBE1E5BC7	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 21.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	56.0
			No	Ramp Width (in)	38.5
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.5.1, R304.5.3</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To W
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	1.0
				X Walk 1 X Slope (%)	2.1
			N/A	Ramp inside XWalk1?	N/A
				Road Slope (%)	1.4
				Road X Slope (%)	0.8
			N/A	Any Obstructions?	N/A
				Obstruction Type	
Total Cost:		\$ 3200.00			
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

