


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 50334	Main Street: LEVY_WY	Cross Street: COMMONWEALTH_AV	Location: NW
ADA ID: 44D268DEBA3F	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		No	Ramp Length (in)	49.0
			Yes	Ramp Width (in)	48.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			No	Painted X Walk1?	N/A
			To S	X Walk 1 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A
			4.5	X Walk 1 Slope (%)	N/A
			1.5	X Walk 1 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>Not Found, R304.2.2, R304.5.3</p>			N/A	Ramp inside XWalk2?	N/A
			2.8	Road Slope (%)	N/A
			4.9	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	N/A
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

Street 1 Name	LEVY WY
Stop Condition-Street 2	StopSign
Street 2 Name	COMMONWEALTH AV
Stop Condition-Street 1	None

Total Cost: \$ 3200.00

