

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 28492	Main Street: TYVOLA CENTRE DR	Cross Street: W TYVOLA RD	Location: NW
ADA ID: 45864231D76A	Ramp Type: Combination2Diag	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 0	

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

R304.5.3, R304.2.2-Perp, R304.3.2-Para

Total Cost: \$ 3200.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	57.0	N/A	Ramp Length RT (in)	N/A
Yes	Ramp Width LT (in)	52.0	N/A	Ramp Width RT (in)	N/A
Yes	Ramp Slope LT (%)	6.5	N/A	Ramp Slope RT (%)	N/A
No	Ramp XSlope LT (%)	3.1	N/A	Ramp XSlope RT (%)	N/A
N/A	Ramp Length (in)	72.0	Yes	Ramp Slope (%)	7.1
Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	1.8
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	Sloped
N/A	Flare Slope LT (%)	9.2	Yes	Flare Slope RT (%)	5.9
N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	Yes
Yes	Landing Length (in)	48.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	3.0	Yes	DWS Length (in)	24.0
Yes	Landing X Slope (%)	1.3	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	0.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	3.0
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.7
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To S		X Walk 2 Direction	To E
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	3.4		X Walk 2 Slope (%)	0.3
	X Walk 1 X Slope (%)	4.1		X Walk 2 X Slope (%)	2.3
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	1.6		Clear Space?	Yes
	Road X Slope (%)	2.1	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstruction?	No
				Obstruction Type	N/A
			Yes	Storm Grate/Utility Hazard?	No
				Storm Grate/Utility Type	N/A
			Yes	Surface Condition? (G/P)	Good
				Curb Slope (%)	0.9

Street 1 Name	StopSign
Stop Condition-Street 1	TYVOLA CENTRE DR
Street 2 Name	None
Stop Condition-Street 2	W TYVOLA RD

