


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 10027019	Main Street: FREELAND_LN	Cross Street: N/A	Location: NE
ADA ID: 463A3CD62238	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 33.75

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance					
	Possible Solutions:						
	<b>Remove &amp; Replace Curb Ramp With Two New Directional Ramps or Equivalent.</b>						
	Surveyor Notes:						
	<b>N/A</b>						
	PROW/ADA:						
	<b>R304.5.1, R304.2.2</b>						
		<b>Compliance</b>	<b>Description</b>	<b>Data</b>	<b>Compliance</b>	<b>Description</b>	<b>Data</b>
		N/A	Ramp Length (in)	33.0	No	Ramp Slope (%)	14.8
		No	Ramp Width (in)	43.0	Yes	Ramp XSlope (%)	0.5
		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
		N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
		N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
		N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
		N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
		N/A	Shared Landing?	N/A			
		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
			X Walk 1 Direction	To W		X Walk 2 Direction	To S
		N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
			X Walk 1 Slope (%)	3.9		X Walk 2 Slope (%)	7.5
			X Walk 1 X Slope (%)	14.3		X Walk 2 X Slope (%)	6.3
		N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
			Road Slope (%)	1.7	N/A	Clear Space?	N/A
			Road X Slope (%)	9.5	N/A	Clear Space to XWalk (in)	N/A
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
			Obstruction Type			Storm Grate/Utility Type	
				N/A			N/A
					Yes	Surface Condition? (G/P)	Good
Total Cost:		\$	3200.00				

Street 1 Name	<b>ENTRANCE</b>
Stop Condition-Street 2	<b>None</b>
Street 2 Name	<b>FREELAND LN</b>
Stop Condition-Street 1	<b>None</b>

