


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 16161	Main Street: E_INDEPENDENCE_BV	Cross Street: CHARLESTON DR	Location:	N
ADA ID: 464AEAF6BD4D	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: Yes	Severity Score: 0.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:	N/A	Compliance	Description	Data
			N/A	Ramp Length (in)	72.0
			Yes	Ramp Width (in)	48.0
			N/A	Flare Type LT	Sloped
			N/A	Flare Slope LT (%)	9.9
			N/A	Flare Traversable LT?	Yes
			Yes	Landing Length (in)	64.0
			Yes	Landing Width (in)	48.0
			Yes	Landing Slope (%)	1.0
			Yes	Landing X Slope (%)	2.4
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>N/A</p>			N/A	Flare Type RT	N/A
			Yes	Flare Slope RT (%)	1.5
			N/A	Flare Traversable RT?	Yes
			Yes	DWS Provided?	Yes
			Yes	DWS Contrast?	Yes
			Yes	DWS Length (in)	24.0
			Yes	DWS Full Width?	Yes
			N/A	DWS Offset (in)	0.0
			N/A	Shared Landing?	No
			Yes	Gutter Ponding?	No
			Yes	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	Yes
				X Walk 1 Direction	To S
			N/A	X Walk 1 Width (in)	120.0
				X Walk 1 Slope (%)	7.6
				X Walk 1 X Slope (%)	3.0
			Yes	Ramp inside XWalk1?	Yes
				Road Slope (%)	N/A
				Road X Slope (%)	N/A
			Yes	Any Obstructions?	No
Total Cost:		\$ 0.00		Obstruction Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

