

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

24.0

99.0

6.0

4.2

3.0

7.4

N/A

No

To S

N/A

4.1

8.8

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Good 14.5

Intersection ID: 10740Main Street: PRYOR_STCross Street: TUCKASEEGEE_RDLocation:NEADA ID: 48603AF6618DRamp Type: Combination1DiagInitial Pass/Fail: FailOverall Compliance: NoSeverity Score:0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

6.0

8.8

N/A

N/A

N/A

Yes

Clear Space?

Any Obstruction?

Obstruction Type

Curb Slope (%)

Clear Space to XWalk (in)

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)



Street 1 Name
Stop Condition-Street 1
Street 2 Name
Stop Condition-Street 2

None
TUCKASEEGEE RD
StopSign
PRYOR ST

Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.1, R304.5.3, R304.3.2

Total Cost:

Compliance Description Data Compliance Description N/A N/A Ramp Length LT (in) 44.0 Ramp Length RT (in) Yes Ramp Width LT (in) 99.0 Yes Ramp Width RT (in) No Ramp Slope LT (%) 16.1 Yes Ramp Slope RT (%) Ramp XSlope LT (%) 4.2 No Ramp XSlope RT (%) No N/A Ramp Length (in) 99.0 Yes Ramp Slope (%) 43.0 No Ramp XSlope (%) No Ramp Width (in) N/A Flare Type LT N/A N/A Flare Type RT N/A N/A N/A Flare Slope LT (%) Flare Slope RT (%) N/A Flare Traversable LT? N/A N/A Flare Traversable RT? N/A Landing Length (in) N/A N/A DWS Provided? N/A N/A **DWS Contrast?** N/A Landing Width (in) N/A Landing Slope (%) N/A N/A DWS Length (in) N/A Landing X Slope (%) N/A N/A DWS Full Width? N/A Landing Curb? (Y/N) N/A N/A DWS Offset (in) N/A Shared Landing? N/A N/A **Gutter Ponding?** N/A N/A Gutter Slope (%) N/A N/A Gutter Lip Ht (in) N/A Gutter X Slope (%) N/A N/A Painted X Walk1? No Painted X Walk2? To W X Walk 1 Direction X Walk 2 Direction X Walk 1 Width (in) N/A X Walk 2 Width (in) 9.0 X Walk 1 Slope (%) X Walk 2 Slope (%) X Walk 1 X Slope (%) 0.9 X Walk 2 X Slope (%) N/A N/A Ramp inside XWalk1? N/A Ramp inside XWalk2?

Road Slope (%)







3200.00