


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10020374		Main Street: BALLANTYNE CORPORATE_P		Cross Street: N/A		Location:		NE											
ADA ID: 4968B7BDEE87		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 8.75											
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance															
				Possible Solutions:		Compliance		Description		Data		Compliance		Description		Data			
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		111.0		N/A		Grade Break?		N/A		N/A	
						No		Ramp Width (in)		47.0		N/A		Grade Break Slope (%)		0.0		0.0	
						Yes		Ramp Slope (%)		6.0		N/A		Grade Break XSlope (%)		0.0			
						Yes		Ramp XSlope (%)		1.8									
						N/A		Flare Type LT		N/A		N/A		Flare Type RT		N/A			
						N/A		Flare Slope LT (%)		N/A		N/A		Flare Slope RT (%)		0.0			
						N/A		Flare Traversable LT?		N/A		N/A		Flare Traversable RT?		N/A			
						N/A		Landing Length (in)		0.0		N/A		DWS Provided?		N/A			
						N/A		Landing Width (in)		0.0		N/A		DWS Contrast?		N/A			
Surveyor Notes: N/A						N/A		Landing Slope (%)		0.0		N/A		DWS Length (in)		N/A			
						N/A		Landing X Slope (%)		0.0		N/A		DWS Full Width?		N/A			
						N/A		Landing Curb? (Y/N)		N/A		N/A		DWS Offset LT (in)		N/A			
						N/A		Shared Landing?		N/A		N/A		DWS Offset RT (in)		N/A			
						N/A		Gutter Ponding?		0.0		N/A		Gutter Slope (%)		N/A			
						N/A		Gutter Lip Ht (in)		0.0		N/A		Gutter X Slope (%)		N/A			
						N/A		Painted X Walk1?		No				Road Slope (%)		3.9			
								X Walk 1 Direction		To SE				Road X Slope (%)		4.9			
								X Walk 1 Width (in)		N/A				Clear Space?		N/A			
								X Walk 1 Slope (%)		3.9		N/A		Clear Space to XWalk (in)		N/A			
PROW/ADA: R304.5.1								X Walk 1 X Slope (%)		4.9		N/A		Storm Grate/Utility Hazard?		N/A			
						N/A		Ramp inside XWalk1?		N/A				Storm Grate/Utility Type					
						N/A		Any Obstructions?		N/A						N/A			
								Obstruction Type				Yes		Surface Condition? (G/P)		Good			
												N/A		N/A		Curb Slope (%)		8.5	
Street 1 Name		ENTRANCE																	
Stop Condition-Street 1		StopSign																	
Street 2 Name		N/A																	
Stop Condition-Street 2		N/A																	
Total Cost:		\$		1600.00															

Street 1 Name	ENTRANCE
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

