


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15624		Main Street: ORDERMORE_AV		Cross Street: SCOTT_AV		Location: N													
ADA ID: 4A0649D1D20F		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 21.25											
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance															
				Possible Solutions:		Compliance		Description		Data		Compliance		Description		Data			
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		44.0		N/A		Grade Break?		N/A			
						No		Ramp Width (in)		41.0		N/A		Grade Break Slope (%)		0.0			
						Yes		Ramp Slope (%)		7.1		N/A		Grade Break XSlope (%)		0.0			
						No		Ramp XSlope (%)		6.2									
						N/A		Flare Type LT		N/A		N/A		Flare Type RT		N/A			
						N/A		Flare Slope LT (%)		N/A		N/A		Flare Slope RT (%)		0.0			
				Surveyor Notes:		N/A		N/A		Flare Traversable LT?		N/A		N/A		Flare Traversable RT?		N/A	
								N/A		Landing Length (in)		0.0		N/A		DWS Provided?		N/A	
								N/A		Landing Width (in)		0.0		N/A		DWS Contrast?		N/A	
								N/A		Landing Slope (%)		0.0		N/A		DWS Length (in)		N/A	
								N/A		Landing X Slope (%)		0.0		N/A		DWS Full Width?		N/A	
				PROW/ADA:		R304.5.1, R304.5.3		N/A		Landing Curb? (Y/N)		N/A		N/A		DWS Offset LT (in)		N/A	
								N/A		Shared Landing?		N/A		N/A		DWS Offset RT (in)		N/A	
								N/A		Gutter Ponding?		0.0		N/A		Gutter Slope (%)		N/A	
								N/A		Gutter Lip Ht (in)		0.0		N/A		Gutter X Slope (%)		N/A	
								N/A		Painted X Walk1?		No				Road Slope (%)		0.0	
										X Walk 1 Direction		To SW				Road X Slope (%)		1.7	
										X Walk 1 Width (in)		N/A				Clear Space?		N/A	
										X Walk 1 Slope (%)		0.0		N/A		Clear Space to XWalk (in)		N/A	
										X Walk 1 X Slope (%)		1.7		N/A		Storm Grate/Utility Hazard?		N/A	
								N/A		Ramp inside XWalk1?		N/A				Storm Grate/Utility Type			
								N/A		Any Obstructions?		N/A						N/A	
										Obstruction Type				Yes		Surface Condition? (G/P)		Good	
												N/A		N/A		Curb Slope (%)		10.8	
				Total Cost:		\$ 1600.00													