


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 30157	Main Street: HARLAND_ST	Cross Street: OLD_PLANK_RD	Location: SE
ADA ID: 4B9943BCC27B	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 10	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		Compliance			Description			Data	
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	95.5	Yes	Ramp Slope (%)	7.7		
			Yes	Ramp Width (in)	97.0	Yes	Ramp XSlope (%)	0.0		
			N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A		
			N/A	Flare Slope LT (%)	4.3	Yes	Flare Slope RT (%)	3.2		
			N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes		
			No	Landing Length (in)	N/A	Yes	DWS Provided?	Yes		
			No	Landing Width (in)	N/A	Yes	DWS Contrast?	Yes		
			No	Landing Slope (%)	N/A	Yes	DWS Length (in)	24.0		
			No	Landing X Slope (%)	N/A	Yes	DWS Full Width?	Yes		
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	6.0		
PROW/ADA:		R304.2.1, R304.2.2-Perp, R304.3.2-Para, R304.5.3, R305.2	N/A	Shared Landing?	No					
			Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	3.7		
			Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.4		
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A		
				X Walk 1 Direction	To NW		X Walk 2 Direction	N/A		
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A		
				X Walk 1 Slope (%)	1.9		X Walk 2 Slope (%)	N/A		
				X Walk 1 X Slope (%)	0.1		X Walk 2 X Slope (%)	N/A		
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A		
				Road Slope (%)	N/A	N/A	Clear Space?	Yes		
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A		
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No		
				Obstruction Type			Storm Grate/Utility Type			
						N/A		N/A		
						Yes	Surface Condition? (G/P)	Good		
Total Cost:		\$ 1850.00								
Street 1 Name			HARLAND ST							
Stop Condition-Street 2			StopSign							
Street 2 Name			N/A							
Stop Condition-Street 1			N/A							

