


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 28584	Main Street: FALCONCREST_DR	Cross Street: HIGHLAND_CREEK_PY	Location: SW
ADA ID: 4BC4EF8AE0DF	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 4	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance			
	Possible Solutions:				
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.				
	Surveyor Notes:				
	N/A				
	PROW/ADA:				
	Not Found, R304.2.1, R304.2.2-Perp, R304.3.2-Para, R304.5.3, R305.2				
	Street 1 Name	HIGHLAND CREEK PY		Stop Condition-Street 2	None
	Street 2 Name	FALCONCREST DR		Stop Condition-Street 1	StopSign
	Total Cost:	\$	3200.00		
Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	42.0	Yes	Ramp Slope (%)	5.1
Yes	Ramp Width (in)	54.0	Yes	Ramp XSlope (%)	1.4
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	1.4	Yes	Flare Slope RT (%)	5.2
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
No	Landing Length (in)	44.0	Yes	DWS Provided?	Yes
No	Landing Width (in)	44.0	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	3.5	Yes	DWS Length (in)	25.0
No	Landing X Slope (%)	3.4	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	3.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.6
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.2
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To NE		X Walk 2 Direction	To NW
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	96.0
	X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	0.5
	X Walk 1 X Slope (%)	0.5		X Walk 2 X Slope (%)	1.1
N/A	Ramp inside XWalk1?	N/A	Yes	Ramp inside XWalk2?	Yes
	Road Slope (%)	0.9	N/A	Clear Space?	Yes
	Road X Slope (%)	0.4	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good

