

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: N/A		Main Street: ARDREY_KELL_RD	Cross Street: WAVERLY_WALK_AV	Location:	SE
ADA ID: 4BF22041EC79		Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 12.5
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
		Possible Solutions:	Compliance	Description	Data
		Remove & Replace Entire Ramp.	N/A	Ramp Length (in)	96.0
Surveyor Notes: N/A			Yes	Ramp Width (in)	103.0
			Yes	Ramp Slope (%)	3.5
PROW/ADA: R304.5.3			No	Ramp XSlope (%)	5.8
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	0.0
			N/A	Landing Width (in)	0.0
			N/A	Landing Slope (%)	0.0
			N/A	Landing X Slope (%)	0.0
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	0.0
			N/A	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	Yes
				X Walk 1 Direction	To N
				X Walk 1 Width (in)	114.0
				X Walk 1 Slope (%)	3.2
				X Walk 1 X Slope (%)	0.2
			N/A	Ramp inside XWalk1?	Yes
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	7.2
		Total Cost:	\$	1600.00	

