

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 22317 Main Street: SHARON_RD Cross Street: N/A Location: Severity Score: 21.25 **Overall Compliance: No** ADA ID: 4CE209B073BD Ramp Type: Perp Initial Pass/Fail: Fail

Codes/Mitigation Info/Possible Solution



Street 1 Name	SHARON ACRES RD
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Possible Solutions: Remove & Replace Entire Ramp. Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.2.2

Total Cost: 1850.00

Field Measurements/Component Compliance						
Compliance Description		Data	Comp	liance Description	Data	
N/A	Ramp Length (in)	60.0	No	Ramp Slope (%)	9.1	
No	Ramp Width (in)	43.0	Yes	Ramp XSlope (%)	0.1	
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
N/A	Shared Landing?	N/A				
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A	
	X Walk 1 Direction	To W		X Walk 2 Direction	N/A	
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
	X Walk 1 Slope (%)	3.2		X Walk 2 Slope (%)	N/A	
	X Walk 1 X Slope (%)	0.4		X Walk 2 X Slope (%)	N/A	
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
	Road Slope (%)	N/A	N/A	Clear Space?	N/A	
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Obstruction Type			Storm Grate/Utility Type		
		N/A			N/A	
			Yes	Surface Condition? (G/P)	Good	





