


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 14939	Main Street: HOLLYFIELD_DR	Cross Street: JENKINS_DR	Location: NW
ADA ID: 4D3E6AE86249	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 1.25	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		Yes	Ramp Length (in)	102.0
			N/A	Ramp Width (in)	48.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p>			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	1.0
			N/A	Painted X Walk1?	No
			N/A	X Walk 1 Direction	To SW
			N/A	X Walk 1 Width (in)	N/A
			N/A	X Walk 1 Slope (%)	3.9
			N/A	X Walk 1 X Slope (%)	1.7
<p>PROW/ADA:</p> <p>Not Found, R304.5.3</p>			N/A	X Walk 2 Direction	N/A
			N/A	X Walk 2 Width (in)	N/A
			N/A	X Walk 2 Slope (%)	N/A
			N/A	X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A
			N/A	Ramp inside XWalk2?	N/A
			N/A	Road Slope (%)	N/A
			N/A	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
			N/A	Obstruction Type	N/A
Total Cost:		\$ 1850.00	N/A	Clear Space?	N/A
			N/A	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Storm Grate/Utility Type	N/A
			Yes	Surface Condition? (G/P)	Good

