

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 28714 Main Street: EAGLE\_CREEK\_DR Cross Street: KEITHWOOD\_PL Location: S

ADA ID: 4DE88E9CD33F Ramp Type: Directional1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 21.25

**Codes/Mitigation Info/Possible Solution** Field Measurements/Component Compliance Possible Solutions: Compliance Description Data Compliance Description Data N/A Grade Break? N/A Ramp Length (in) 25.0 N/A Remove & Replace Entire Ramp. N/A No Ramp Width (in) 47.0 Grade Break Slope (%) 0.0 N/A No Ramp Slope (%) 9.8 Grade Break XSlope (%) 0.0 Ramp XSlope (%) 0.9 Yes N/A Flare Type LT N/A N/A Flare Type RT N/A N/A Flare Slope LT (%) N/A N/A Flare Slope RT (%) 0.0 Surveyor Notes: N/A Flare Traversable LT? N/A N/A Flare Traversable RT? N/A 0.0 N/A **DWS Provided?** N/A N/A Landing Length (in) N/A N/A Landing Width (in) 0.0 N/A **DWS Contrast?** N/A N/A Landing Slope (%) 0.0 N/A DWS Length (in) N/A N/A N/A Landing X Slope (%) 0.0 DWS Full Width? N/A PROW/ADA: N/A Landing Curb? (Y/N) N/A N/A DWS Offset LT (in) N/A R304.5.1, R304.2.2 N/A Shared Landing? N/A N/A DWS Offset RT (in) N/A N/A **Gutter Ponding?** 0.0 N/A Gutter Slope (%) N/A N/A Gutter Lip Ht (in) 0.0 N/A Gutter X Slope (%) N/A N/A Painted X Walk1? No Road Slope (%) 3.3 **KEITHWOOD PL** To NW Street 1 Name X Walk 1 Direction Road X Slope (%) 1.4 Stop Condition-Street 1 StopSign X Walk 1 Width (in) N/A Clear Space? N/A N/A 3.3 N/A N/A Street 2 Name X Walk 1 Slope (%) Clear Space to XWalk (in) Stop Condition-Street 2 N/A X Walk 1 X Slope (%) 1.4 N/A Storm Grate/Utility Hazard? N/A N/A Ramp inside XWalk1? N/A Storm Grate/Utility Type N/A N/A Any Obstructions? N/A Total Cost: **Obstruction Type** Surface Condition? (G/P) 1600.00 Yes Good N/A N/A Curb Slope (%) N/A





