


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10022109	Main Street: BULFINCH_RD	Cross Street: N/A	Location: S
ADA ID: 4ED65A6990B6	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		No	Ramp Length (in)	9.4
			Yes	Ramp Width (in)	0.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>Not Found, R304.2.2</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
<p>Total Cost:</p> <p>\$ 1850.00</p>			No	Painted X Walk2?	N/A
			To N	X Walk 2 Direction	N/A
			N/A	X Walk 2 Width (in)	N/A
			2.8	X Walk 2 Slope (%)	N/A
			1.7	X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk2?	N/A
			N/A	Clear Space?	N/A
			N/A	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Storm Grate/Utility Type	N/A
<p>Street 1 Name</p> <p>BULFINCH RD</p> <p>Stop Condition-Street 2</p> <p>None</p> <p>Street 2 Name</p> <p>N/A</p> <p>Stop Condition-Street 1</p> <p>N/A</p>			N/A	Surface Condition? (G/P)	Good

