

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Yes

Surface Condition? (G/P)

Good

Intersection ID: N/A	Main Street: MAXAM CT			street:	N/A	Location:	SE		
ADA ID: 4F380CE0A999	9 Ramp Type: Perp			Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	30
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
		Possible Solutions:		Compliance Description D			Data Compliance Description		
	1	Remove & Replace Entire Ramp).	N/A	Ramp Length (in)	95.0	No	Ramp Slope (%)	8.5
	1 7 2			No	Ramp Width (in)	35.0	Yes	Ramp XSlope (%)	1.5
	-			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
	Martin			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
Tage \	and and	Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
	I SHE	N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
Mar.	ANT IN			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
The second of th	and the second second			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1				N/A	Shared Landing?	N/A			
the total		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
	(Population)	Not Found, R304.5.1, R304.2.2		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
A LAND	No.			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
the states	AND THE POLY				X Walk 1 Direction	To W		X Walk 2 Direction	N/A
A CARLES AND	12010			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	МАХАМ СТ				X Walk 1 Slope (%)	2.1		X Walk 2 Slope (%)	N/A
Stop Condition-Street 2	None				X Walk 1 X Slope (%)	0.2		X Walk 2 X Slope (%)	N/A
Street 2 Name	N/A			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	N/A				Road Slope (%)	N/A	N/A	Clear Space?	N/A
					Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost: \$	1850.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A