

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Data

N/A

N/A

N/A

N/A

3.6

2.1

N/A

No

N/A

2.2

4.6

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Good 9.9

To NW

Intersection ID: 17277 Main Street: AYCOCK LN Cross Street: SCALEYBARK RD S Location: **Overall Compliance: No Severity Score:** 0 ADA ID: 506C1DC51044 Ramp Type: Combination2Diag Initial Pass/Fail: Fail

**Codes/Mitigation Info/Possible Solution** 

## Field Measurements/Component Compliance

N/A

N/A

N/A

N/A

Yes

No

N/A

Compliance Description

Ramp Length RT (in)

Ramp Width RT (in)

Ramp Slope RT (%)

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

**DWS Contrast?** 

DWS Length (in)

DWS Full Width?

DWS Offset (in)

Gutter Slope (%)

Gutter X Slope (%)

Painted X Walk2?

X Walk 2 Direction

X Walk 2 Width (in)

X Walk 2 Slope (%)

X Walk 2 X Slope (%)

Ramp inside XWalk2?

Clear Space?

Flare Traversable RT?

Ramp XSlope RT (%)

Data

77.0

34.5

7.5

2.2

24.0

48.0

N/A

No

N/A

4.1

1.9

N/A

3.0

To NE



Street 1 Name Stop Condition-Street 1 Street 2 Name Stop Condition-Street 2


None SCALEYBARK RD StopSign AYCOCK LN Possible Solutions: Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.5.3

Total Cost:

Compliance Description N/A Ramp Length LT (in) No Ramp Width LT (in) Yes Ramp Slope LT (%) Ramp XSlope LT (%) No N/A Ramp Length (in) Yes Ramp Width (in) N/A Flare Type LT N/A Flare Slope LT (%) N/A Flare Traversable LT? N/A Landing Length (in) N/A Landing Width (in) N/A Landing Slope (%) N/A Landing X Slope (%) N/A Landing Curb? (Y/N) N/A Shared Landing? N/A Gutter Ponding? N/A Gutter Lip Ht (in) N/A Painted X Walk1? X Walk 1 Direction X Walk 1 Width (in)

N/A

3200.00



X Walk 1 Slope (%)

X Walk 1 X Slope (%)

Ramp inside XWalk1?

Road Slope (%)



