


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 25032	Main Street: CARMEL_RD	Cross Street: SHADOWLAKE_DR	Location: NW
ADA ID: 52EF21236124	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		No	Ramp Length (in)	60.0
			Yes	Ramp Width (in)	51.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p>			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To SW
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	1.3
				X Walk 1 X Slope (%)	8.7
			N/A	Ramp inside XWalk1?	N/A
<p>PROW/ADA:</p> <p>R304.2.2, R304.5.3</p>			N/A	Road Slope (%)	1.3
				Road X Slope (%)	0.3
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good
Total Cost:		\$ 3200.00			

Street 1 Name	SHADOWLAKE DR
Stop Condition-Street 2	None
Street 2 Name	CARMEL RD
Stop Condition-Street 1	None

