

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

52.0

56.0

9.3

8.0

3.0

3.6

N/A

No

To S

N/A

0.4

2.9

N/A

N/A

N/A

Intersection ID: 14004 Main Street: ELMIN_ST Cross Street: OLD_STEELE_CREEK_RD Location: NE
ADA ID: 55516F72C4AF Ramp Type: Combination1Diag Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

0.6

N/A

3.3

2.3 N/A

N/A



Street 1 Name
Stop Condition-Street 1
Street 2 Name
Stop Condition-Street 2

None
OLD STEELE CREEK RD
StopSign
ELMIN ST

Possible Solutions:

Remove & Replace Curb Ramp With
Two New Directional Ramps or
Equivalent.


Surveyor Notes:

LT RP < 5%

PROW/ADA:

R304.5.3, R304.3.2

Total Cost:



X Walk 1 X Slope (%)

Ramp inside XWalk1?

Road Slope (%)







N/A

3200.00

	. ,	
N/A	Any Obstruction?	N/A
	Obstruction Type	
		N/A
N/A	Storm Grate/Utility Hazard?	N/A
	Storm Grate/Utility Type	
		N/A
Yes	Surface Condition? (G/P)	Good
	Curb Slope (%)	3.5

X Walk 2 X Slope (%)

Ramp inside XWalk2?

Clear Space to XWalk (in)

Clear Space?