

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 10032835 Main Street: NATIONS_FORD_RD Cross Street: N/A Location: SW Overall Compliance: No **Severity Score: ADA ID: 55DF7D2D438E** Ramp Type: Perp Initial Pass/Fail: Fail 12.5

Codes/Mitigation Info/Possible Solution



SC / / X (g)	AND AND ADDRESS OF THE PARTY OF
Street 1 Name	NATIONS FORD RD
Stop Condition-Street 2	None
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Possible Solutions:	9
Remove & Replace Entire Ramp.	
	•
	ı
	I
	ı
	I
Surveyor Notes:	ı
N/A	ı
	ı
	I
	I
PROW/ADA:	I
Not Found, R304.2.2	ı
	I
	ı
	I

TP.Ite	Gardig.	67 HIGH
		7-



Total Cost:



1850.00

Field Measurements/Component Compliance							
Comp	liance Description	Data	Comp	liance Description	Data		
N/A	Ramp Length (in)	53.0	No	Ramp Slope (%)	10.5		
Yes	Ramp Width (in)	54.0	Yes	Ramp XSlope (%)	0.9		
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A		
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A		
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A		
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A		
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A		
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A		
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A		
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A		
N/A	Shared Landing?	N/A					
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A		
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A		
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A		
	X Walk 1 Direction	To E		X Walk 2 Direction	N/A		
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A		
	X Walk 1 Slope (%)	1.9		X Walk 2 Slope (%)	N/A		
	X Walk 1 X Slope (%)	2.4		X Walk 2 X Slope (%)	N/A		
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A		
	Road Slope (%)	N/A	N/A	Clear Space?	N/A		
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A		
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A		
	Obstruction Type			Storm Grate/Utility Type			
		N/A			N/A		
			Yes	Surface Condition? (G/P)	Good		