


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 11627	Main Street: CARLYLE_DR	Cross Street: CARTWRIGHT_PL	Location:	N
ADA ID: 5630D8BDEF4B	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 10

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		Compliance	Description	Data	
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	27.0	Yes
			No	Ramp Width (in)	44.5	No
			N/A	Flare Type LT	N/A	N/A
			N/A	Flare Slope LT (%)	N/A	N/A
			N/A	Flare Traversable LT?	N/A	N/A
			N/A	Landing Length (in)	N/A	N/A
			N/A	Landing Width (in)	N/A	N/A
			N/A	Landing Slope (%)	N/A	N/A
			N/A	Landing X Slope (%)	N/A	N/A
<p>Surveyor Notes:</p> <p>N/A</p>			N/A	Landing Curb? (Y/N)	N/A	N/A
			N/A	Shared Landing?	N/A	
			N/A	Gutter Ponding?	N/A	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A
			N/A	Painted X Walk1?	No	N/A
				X Walk 1 Direction	To S	N/A
			N/A	X Walk 1 Width (in)	N/A	N/A
				X Walk 1 Slope (%)	0.0	N/A
				X Walk 1 X Slope (%)	3.9	N/A
			N/A	Ramp inside XWalk1?	N/A	N/A
<p>PROW/ADA:</p> <p>Not Found, R304.5.1, R304.5.3</p>				Road Slope (%)	N/A	N/A
				Road X Slope (%)	N/A	N/A
			N/A	Any Obstructions?	N/A	N/A
				Obstruction Type		
<p>Total Cost:</p> <p>\$ 1850.00</p>						

