

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 50710	Main Street: STEELE_CREEK_RD	Cross Street: ARRIVAL_DR	Location: SW
ADA ID: 57EF80457FCC	Ramp Type: Para	Initial Pass/Fail: Pass	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Landing.
Remove & Replace Sidewalk.

Surveyor Notes:

RT RP < 5%

PROW/ADA:

R304.5.3, R304.2.1

Street 1 Name	STEELE CREEK RD
Stop Condition-Street 1	None
Street 2 Name	N/A
Stop Condition-Street 2	N/A

Total Cost: \$ 900.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	51.5	N/A	Ramp Length RT (in)	70.5
Yes	Ramp Width LT (in)	49.0	Yes	Ramp Width RT (in)	50.0
Yes	Ramp Slope LT (%)	7.4	Yes	Ramp Slope RT (%)	2.9
Yes	Ramp XSlope LT (%)	1.1	No	Ramp XSlope RT (%)	3.4
Yes	Landing Length (in)	96.0	Yes	DWS Provided?	Yes
No	Landing Width (in)	46.0	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	1.7	Yes	DWS Length (in)	24.5
Yes	Landing X Slope (%)	2.4	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	1.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	0.4
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	2.5
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To E		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	7.0		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	2.5		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	Yes
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			Compliant	Curb Slope (%)	4.6

